



CITY OF DULUTH
PURCHASING DIVISION
Room 100 City Hall
411 West First Street
Duluth, Minnesota 55802-1199
218/730-5340 218/730-5922 FAX
purchasing@duluthmn.gov

Addendum 2
File # 17-0169
SP No. 118-090-023
MN Project No. TA 6917(230)

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Instructions to Bidders:

All rebar referenced in plan and specifications shall be epoxy coated.

Page 7 of the Plan Set:

Construction Joint Reinforcement

Remove No. 16 Bar, 6' long

Replace with No. 8 Bar, 6' long

Wall Notes:

Remove (Dowel Bar Assemblies, No. 16 Reinforcing Bars, Joint Filler, and Joint Waterproofing)

Replace with (Dowel Bar Assemblies, No. 8 Reinforcing Bars, Joint Filler, and Joint Waterproofing)

Please acknowledge receipt of this Addendum by initialing and dating Addendum #2 below the bid form on the invitation for bids.

Posted: June 12, 2017